CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0595:109 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Ansul Fire Protection, One Stanton Street, Marinette, WI 54143

Contact: Lyle McDonald (715) 732-3601

DESIGN: Model AUTOPULSE IQ301 control unit. Local, auxiliary, remote station, proprietary, central

station and releasing device service. Refer to listee's data sheet for detailed product

description and operational considerations.

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories

shall be CSFM listed. Accessories included in this listing:

BB-17 battery box

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible initiating and indicating

devices. Suitable for central station service when used with Model 911A communicator

(CSFM Listing No. 7165-0075:152)

This control unit does not generate a temporal pattern signal. If the distinctive threepulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation

Manual for details.

XLF: 7165-0028:164

07-25-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 10, 2002 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager